



This Drawing is NOT Automatically updated when changes are made. A newer Version maybe used for Production.

> 1. RACK MOUNTED STEEL CHASSIS BLACK MEDIUM TEXTURE 19.00" WIDE STANDARD RACK MOUNTING 1.72" HIGH 7.00" DEEP CHASSIS SUPPORT BRACKETS ARE REQUIRED

2. INPUT: 240 VAC 24A SINGLE PHASE, 50/60 HZ POWER CABLE: 15 FEET 10/3 SOOW CABLE POWER PLUG: L6-30 PLUG

3. OUTPUT: 240 VAC 12 AMPS, SINGLE PHASE 50/60 HZ AT TWELVE NEMA 6-15 RECEPTACLES J1 - J2, J9 - J12 CONTROLLED BY CB1, 12 AMP MAX J3 - J8 CONTROLLED BY CB2, 12 AMP MAX


- 4. CIRCUIT BREAKERS: TWO MAGNETIC, 2-POLE 15A UL LISTED HIGH-INRUSH LONG TIME DELAY
- 5. INDICATOR LIGHTS: 2 BLUE, ON WHEN CORRESPONDING BREAKER IS ON
- 6. FILTER: 30 AMP SINGLE PHASE COMMON MODE: LINE TO GROUND; DIFFERENTIAL MODE: LINE TO LINE
- 7. SPIKE/SURGE SUPPRESSION: LINE TO LINE

SMTP (E-MAIL NOTIFICATION)

8. CURRENT METER READS TRUE RMS CURRENT AT LOCAL DISPLAY AND ETHERNET (RJ45 PORT) INTERFACES: WEB (HTTP) SNMP

ACCURACY: ± 3.0% OR 0.1A FOR SINE WAVE, WHICHEVER IS GREATER RESOLUTION: 1 AMP LOCAL DISPLAY RANGE: 0-30 AMPS 7-FOOT CAT-5 CABLE INCLUDED

- 9. UL/cUL LISTED PRODUCT
- 10. RoHS COMPLIANT PER DIRECTIVE 2002/95/EC WITH APPLICABLE EXEMPTIONS



THE INFORMATION AND DESIGN DISCLOSED HEREIN WAS ORIGINATED BY AND IS THE PROPERTY OF EATON CORPORATION. EATON CORPORATION RESERVES ALL PATENT, PROPEITARY, DESIGN, MANUFACTURING, REPRODUCTION, USE AND SALE RIGHTS THERETO, MANUFACTURING, REPRODUCTION, USE AND SALE RISSTIC FIELDS 19, 2007.

AND TO ANY ARTICLE DISCLOSED THEREIN, EXCEPT TO THE EXTENT 2009 EXTENT 2019 EXTENT 2019 EATON CORP CAGE CODE 70513

CAGE CODE 70513

DRAWN BY: LSANDOVAL DWG OTHER STATEMENT AND THE CONTROL OF THE CONTROL

3200 S. Susan Street, Santa Ana, CA 92704 Phone (714) 540-4229 Fax (714) 641-9062 www.epdu.com **ENGINEERING DRAWING FOR**

DIMENSIONS IN INCHES
TOLERANCES:
DECIMALS ANGLES
XX ± 0.5°
±.020
XXX UNLESS
0THERWISE
\$PECIFIED T982F1-F-SL-115 ASSY. 3190 DRAWN BY: L.SANDOVAL DWG FILENAME: T_982F1_F_LS_116_3190B_ME.DWG T_982F1_F_LS_115_3190B_ME